



Township of Southgate

Dundalk Waterworks

2021 Annual Report

Jim Ellis
Public Works Manager

Dundalk Waterworks 2021 Annual Report

Table of Contents

Township of Southgate Annual Water Report.....	1
Summary of all Test Results.....	2
Average Day Well Consumption vs. Maximum Flow/Day Allowed.....	4
Maximum One Day Well Consumption vs. Maximum Flow Allow.....	5
Total Well Consumption vs. Maximum Flow Allowed.....	6
Ministry of the Environment Annual Report.....	7
Annual Sampling Results.....	15
Distribution System Bacteriological Data – Annual Summary.....	16
Input into the Distribution System Bacteriological Data – Treated Water Well 3.....	17
Input into the Distribution System Bacteriological Data – Treated Water Well 4.....	18
Input into the Distribution System Bacteriological Data – Treated Water Well 5.....	19
Raw Water Bacteriological Data –Well 3.....	20
Raw Water Bacteriological Data –Well 4.....	21
Raw Water Bacteriological Data –Well 5.....	22
Input into the Distribution System Bacteriological Data – Chlorine Residuals Well 3.....	23
Input into the Distribution System Bacteriological Data – Chlorine Residuals Well 4.....	24
Input into the Distribution System Bacteriological Data – Chlorine Residuals Well 5.....	25
Fluoride, Nitrite, Nitrate and Colour – Well 3.....	26
Fluoride, Nitrite, Nitrate and Colour – Well 4.....	27
Fluoride, Nitrite, Nitrate and Colour – Well 5.....	28
Treated Water Volatile Organic & Inorganic Data – Well 3.....	29
Treated Water Volatile Organic & Inorganic Data – Well 4.....	30
Treated Water Volatile Organic & Inorganic Data – Well 5.....	31
Parameters Not Listed in the Minimum Sampling Program – Well 3.....	32
Parameters Not Listed in the Minimum Sampling Program – Well 4.....	33
Parameters Not Listed in the Minimum Sampling Program – Well 5.....	34
Distributed Water Volatile Organic & Inorganic Data.....	35

Dundalk Waterworks - Township of Southgate

2021 Annual Water Report

Site: Village of Dundalk
Operations Address: 75 Dundalk Street,
Dundalk, Ontario N0C 1B0
Waterworks #: 220001753
Municipal Drinking Water Licence: 110-101, Issue No. 5
Drinking Water Works Permit: 110-201, Issue No. 5
Period of this Report: January 1- December 31 **Year:** 2021

Description of System

The water system known as Dundalk Water Works is a ground water source consisting of three production wells, one monitoring well and a distribution system. The system is monitored by a SCADA system installed in 2006 which communicates through RF towers and PLC's in the wells to record data and monitor operations.

Well D3 is equipped with a submersible pump, flow meter, two ultra violet sterilization chambers and a chemical feed pump for sodium hypochlorite and is connected to a 1365 m³ baffled storage tank with 2 pax mixers. Two turbine high lift pumps pump from storage through a flow meter into a distribution system and a booster chemical feed pump are connected after the reservoir and starts automatically if the chlorine residual begins to fall. This well has a capacity of 1182 m³/day. This pump house is equipped with two chlorine analyzers, one prior to the reservoir and the second installed prior to entering the distribution system. The entire system is under the control of a PLC system and any failures alarm a dial out system to alert operators. Well D3 is equipped with an 80 kW diesel generator that starts automatically in the event of a power outage and is capable of providing power to maintain this water supply.

Well D4 was constructed in 2004 and is equipped with a submersible pump, flow meter and a chemical feed pump for sodium hypochlorite and is connected to a 187.7 m³ baffled reservoir. Two turbine high lift pumps pump from storage through a flow meter into a distribution system and a booster chemical feed pump is connected after the reservoir that automatically starts if the chlorine residual begins to fall. This well has a 1637 m³/day capacity. This pump house is equipped with two chlorine analyzers, one prior to the reservoir and the second installed prior to entering the distribution system. The entire system is under the control of a PLC system and any failures alarm a dial out system to alert operators. Well D4 is equipped with a 100 kW diesel generator with automatic transfer switch for standby power.

Well D5 was drilled in 2017 with the well house and reservoir built in 2019. It is equipped with a 15hp submersible pump that fills a rectangular baffled reservoir with a capacity of 536 cubic meters. Two turbine high lift pumps pump from storage through a flow meter into a distribution system and a booster chemical feed pump is connected after the reservoir that automatically starts if the chlorine residual begins to fall. This well has a 1961 m3/day capacity. This pump house is equipped with two chlorine analysers, one prior to the reservoir and the second installed prior to entering the distribution system. The entire system is under the control of a PLC system and any failures alarm a dial out system to alert operators. Well D5 is equipped with a 150 kW diesel generator with automatic transfer switch for standby power.

The distribution system is made up of a network of water mains of varying size with 1,318 service connections.

Summary of all Test Results

Treated Water Recap:

No. of Distribution Samples taken	210
No. of Treated Water Well Samples taken	158
No. of samples with Total Coliform	0
No. of samples with E Coli	0
No. of treated samples with Heterotrophic Plate Count >500	1

Raw Water Recap:

No. of Raw Water Well Samples taken	156
No. of Raw samples with Total Coliform	5
No. of Raw samples with E Coli	1
No. of Raw samples with Heterotrophic Plate Count > 500	1

Heterotrophic Plate Counts are conducted on some treated and distribution system samples. The HPC test is used as a tool to monitor overall quality, but the results are not indicators of water safety. There is not a Drinking Water Quality Standard for HPC.

Summary of Adverse Test Results Reported: -

Adverse Sodium results which are not reportable.

Description of Corrective Action Taken:

- The Health Unit was advised to notify users and information was put on the back of the water bills.

Description of Major Equipment Expenses:

- Rowes Lane watermain upgrade =\$128,389.12
- Water Tower design and engineering = \$2,974.48
- Victoria Street pre-engineering design \$1,836.77
- Glenelg Street watermain upgrade \$1,602.72
- Purchased water meters = \$25,343.32
- Debt Well D5/ Main St E was \$127,001

New Equipment Installed:

Nothing to report.

Equipment Replaced:

2 – 6" Watermain valves \$1,231.30

Repairs to Equipment:

Well D3 generator radiator replacement \$4,943.67

Frozen Water:

Nothing to report.

Township of Southgate - Dundalk Waterworks
Average Day Well Consumption vs. Maximum Flow/Day Allowed Report 2021

Month	Average Day Water Consumption Well #3	Maximum Flow Rate Allowed Well #3/Day	Average Day Water Consumption Well #4	Maximum Flow Rate Allowed Well #4/Day	Average Day Water Consumption Well #5	Maximum Flow Rate Allowed Well #5/Day	Average Day Water Consumption All Wells	Maximum Flow Rate Allowed All Wells/Day
January	219	1,182	203	1,637	221	1,961	643	2,817
February	215	1,182	224	1,637	181	1,961	620	2,817
March	216	1,182	211	1,637	206	1,961	633	2,817
April	212	1,182	184	1,637	202	1,961	598	2,817
May	219	1,182	226	1,637	198	1,961	643	2,817
June	216	1,182	321	1,637	208	1,961	745	2,817
July	216	1,182	216	1,637	200	1,961	632	2,817
August	222	1,182	182	1,637	270	1,961	674	2,817
September	216	1,182	198	1,637	195	1,961	609	2,817
October	215	1,182	223	1,637	206	1,961	644	2,817
November	217	1,182	244	1,637	196	1,961	657	2,817
December	216	1,182	304	1,637	202	1,961	722	2,817
Annual Monthly Average in M₃	217	1,182	228	1,637	207	1,961	652	2,817

Note: Flow in above chart is in Cubic Meters

Certificate of Approval Well Pumping Maximum Flow Rate per Day

Well	Maximum Pump Rate in Liters/Min.	Maximum Pump Rate in Liters/Day	Maximum Pump Rate in m ³ /Day	Maximum Pump Rate in Gallons/Day
Well #3	820	1,180,800	1181	259,985
Well #4	1137	1,637,280	1636	360,149
Well #5	1362	1,961,280	1961	431,695
Total			2817	620,134

Township of Southgate - Dundalk Waterworks
Maximum One Day Well Consumption vs. Maximum Flow Allowed Report 2021

Month	Maximum One Day Consumption Well #3	Maximum Flow Allowed/Day Well #3	Maximum One Day Consumption Well #4	Maximum Flow Allowed/Day Well #4	Maximum One Day Consumption Well #5	Maximum Flow Allowed/Day Well #5	Maximum One Day Flow All Wells	Maximum Flow Allowed/Day All Wells
January	297	1,182	512	1,637	414	1,961	887	2,817
February	393	1,182	442	1,637	379	1,961	898	2,817
March	313	1,182	260	1,637	772	1,961	772	2,817
April	320	1,182	251	1,637	294	1,961	725	2,817
May	341	1,182	474	1,637	254	1,961	909	2,817
June	331	1,182	525	1,637	343	1,961	1,004	2,817
July	315	1,182	301	1,637	252	1,961	837	2,817
August	345	1,182	408	1,637	542	1,961	910	2,817
September	335	1,182	255	1,637	320	1,961	791	2,817
October	248	1,182	438	1,637	517	1,961	842	2,817
November	330	1,182	452	1,637	213	1,961	889	2,817
December	358	1,182	501	1,637	381	1,961	884	2,817
Annual Maximum for One Day - m³	393	1182	525	1637	772	1961	1004	2817
Annual Maximum for One Day - Gal	86,515	260,205	115,574	360,369	169,948	431,695	221,021	620,134

Note: Flow in above chart is in Cubic Meters

Certificate of Approval Well Pumping Maximum Capacity per Day

Well	Maximum Pump Rate in Liters/Min.	Maximum Pump Rate in Liters/Day	Maximum Pump Rate in m ³ /Day	Maximum Pump Rate in Gallons/Day
Well #3	822	1,183,680	1181	259,985
Well #4	1134	1,632,960	1636	360,149
Well #5	1362	1,961,280	1961	431,695
Total			2817	620,134

Township of Southgate - Dundalk Waterworks
Total Well Consumption vs. Maximum Flow Allowed Report 2021

Month	Water Consumption Well #3	Monthly Flow Allowed Well #3	Water Consumption Well #4	Monthly Flow Allowed Well #4	Water Consumption Well #5	Monthly Flow Allowed Well #5	# of Days in Month
January	6,776	36,611	6,290	50,716	6,846	60,791	31
February	6,015	33,068	6,259	45,808	5,060	54,908	28
March	6,694	36,611	6,554	50,716	6,388	60,791	31
April	6,370	35,430	5,520	49,080	6,062	58,830	30
May	6,777	36,611	7,018	50,716	6,136	60,791	31
June	6,485	35,430	9,618	49,080	6,248	58,830	30
July	6,711	36,611	6,685	50,716	6,204	60,791	31
August	6,870	36,611	5,636	50,716	8,364	60,791	31
September	6,486	35,430	5,934	49,080	5,848	58,830	30
October	6,667	36,611	6,903	50,716	6,375	60,791	31
November	6,499	35,430	7,319	49,080	5,875	58,830	30
December	6,686	36,611	9,435	50,716	6,254	60,791	31
Annual Flow in m3	79,036	431,065	83,171	597,140	75,660	715,765	

Certificate of Approval Well Pumping Maximum Flow Rate per Day

Well	Maximum Pump Rate in Liters/Min.	Maximum Pump Rate in Liters/Day	Maximum Pump Rate in m ³ /Day	Maximum Pump Rate in Gallons/Day	Water Consumption in m3 by Well in 2019	Annual Flow Allowed at each Wells
Well #3	822	1,183,680	1181	259,985	79,036	431,065
Well #4	1134	1,632,960	1636	360,149	83,171	597,140
Well #5	1362	1,961,280	1961	431,695	75,660	715,765
Total			2817	620,134	237,867	1,743,970

OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	220001753
Drinking-Water System Name:	Dundalk Waterworks
Drinking-Water System Owner:	Township of Southgate
Drinking-Water System Category:	Large Municipal – Residential
Period being reported:	January 1 to December 31, 2021

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <ul style="list-style-type: none"> • Southgate Municipal Office (near Hopeville) 185667 Grey Road 9, RR 1 Dundalk ON N0C 1B0 • Dundalk Works Depot 75 Dundalk St Dundalk ON N0C 1B0 • Dundalk Library 80 Proton Street North </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served:</p> <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">3</div> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [x] No []</p> <p>Number of Interested Authorities you report to:</p> <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">3</div> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [x] No []</p>
---	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
 Yes [] No [x]

Indicate how you notified system users that your annual report is available, and is free of charge.

- ☒ Public access/notice via the web
☒ Public access/notice via Government Office
☒ Public access/notice via a newspaper
☒ Public access/notice via Public Request
☒ Public access/notice via a Public Library
☐ Public access/notice via other method _____

Describe your Drinking-Water System

Dundalk Waterworks has three operational wells. The Township has a 1306 m³ of storage in an above ground baffled reservoir at Well 3, a 187.7 m³ baffled reservoir at Well D4 and a 536 m³ baffled reservoir at Well D5. The water is pumped by high lift pumps into the distribution system from one of the reservoirs. All wells communicate by RF towers to control which well is in the lead and are monitored by SCADA through the same communications system.

List all water treatment chemicals used over this reporting period

Sodium Hypochlorite

Were any significant expenses incurred to?

- ☐ Install required equipment
☒ Repair required equipment
☒ Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Well D3 generator radiator replacement \$4,943.67

- Rowes Lane watermain upgrade =\$128,389.12
- Water Tower design and engineering = \$2,974.48
- Victoria Street pre-engineering design \$1,836.77
- Glenelg Street watermain upgrade \$1,602.72
- Purchased water meters = \$25,343.32
- Debt Well D5/ Main St E was \$127,001

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
12/7/21	Sodium	28.5	Mg/L	N/R	N/A
12/7/21	Sodium	30.0	Mg/L	N/R	N/A
1/3/21	Sodium	31.6	Mg/L	N/R	N/A
1/3/21	Sodium	30.2	Mg/L	N/R	N/A
7/6/20	Sodium	31.6	Mg/L	N/R	N/A
7/6/20	Sodium	27.6	Mg/L	N/R	N/A
3/9/20	Sodium	29.5	Mg/L	N/R	N/A
3/9/20	Sodium	30.2	Mg/L	N/R	N/A
7/2/19	Sodium	26.7	Mg/L	N/R	N/A
7/2/19	Sodium	25.0	Mg/L	N/R	N/A
3/4/19	Sodium	23.5	Mg/L	N/R	N/A
3/4/19	Sodium	22.8	Mg/L	N/R	N/A
3/9/18	Sodium	36.3	Mg/l	Re-sampled	3/13/18
3/9/18	Sodium	31.9	Mg/l	Re-sampled	3/13/18
3/5/18	Sodium	36.3	mg/l		
3/6/17	Sodium	28.2	mg/l	N/R	N/A
7/5/16	Sodium	28	mg/l	N/R	N/A
3/10/16	Sodium	28.8	mg/l	Re-sampled	7/5/16
3/9/15	Sodium	28.7	mg/l	N/R	N/A
3/3/14	Sodium	31.5	mg/l	Re-sampled	3/3/14
3/14/13	Sodium	30.2	mg/l	Re-sampled	3/14/13
3/14/13	Sodium	23.7	mg/l	Re-sampled	3/14/13

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	156	0-1	0-6	156	0-750
Treated	159	0-0	0-0	159	0-2000
Distribution	210	0-0	0-0	210	0-270

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	36	0.04 - 0.11
Chlorine	365 8760 – D3 8760 – D4 8760 – D5	Distribution Free 0.34 – 1.45 Treated Free 0.77 – 1.57 Treated Free 0.80 – 1.43 Treated Free 0.70 – 1.30
Fluoride (If the DWS provides fluoridation)		

NOTE: For continuous monitors use 8760 as the number of samples.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
Drinking Water License 110-101 Issue Number 5 (01/28/2021), Permit 110-201 Issue Number 5 (01/28/2021),	Sodium	12/7/21	D3-30.0 D4-28.5 D5-15.9	Mg/L
		1/3/21	D3-31.6 D4-30.2 D5-17.2	
	Radionuclides	1/3/21		
	D3 Gross Alpha	“	<0.10	Bq/L
	D3 Gross Beta	“	0.15	Bq/L
	D3 Tritium	“	<15	Bq/L
	D4 Gross Alpha	“	0.12	Bq/L
	D4 Gross Beta	“	0.11	Bq/L
	D4 Tritium	“	<15	Bq/L
	D5 Gross Alpha	“	0.11	Bq/L
	D5 Gross Beta	“	0.1	Bq/L
	D5 Tritium	“	<15	Bq/L
Drinking Water License 110-101(01/02/2016), Permit 110-201(02/02/2016)	Sodium	3/9/20	D3-29.5 D4-30.2 D5-16.3	mg/l
		7/6/20	D3-31.6 D4-27.6 D5-15.7	
“	Sodium	3/8/19	D3-22.8 D4-23.5	mg/l
“	Sodium	3/6/17	D3-28.2 D4-26.3	mg/l

“	Sodium	July 5/16	D3-27.9 D4-28	mg/l
“	Sodium	March 8/16	D3-28.8 D4-27.7	mg/l
“	Sodium	March 9/15	D3-28.7	mg/l
“	Sodium	”	D4 – 18.1	mg/l
“	Radionuclides	March 16/19		ug/l
“	D3 Gross Alpha	”	0.13	“
“	D3 Gross Beta	“	<0.10	“
“	D3 Tritium	“	<15	“
“	D4 Gross Alpha	“	0.12	“
“	D4 Gross Beta	“	<0.10	“
“	D4 Tritium	“	<15	“

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	March/1/21	<0.0001	mg/l	
Arsenic	March/1/21	D3-0.0012 D4-0.0003 D5-0.0008	“	
Barium	March/1/21	D3-0.105 D4-0.096 D5-0.105	“	
Boron	March/1/21	D3-0.054 D4-0.040 D5-0.048	“	
Cadmium	March/1/21	D3-<0.000015 D4-<0.000015 D5-<0.000015	“	
Chromium	March/1/21	D3-<0.002 D4-<0.002 D5-<0.002	“	
*Lead	March 16-18/21 Sept 23/21 to Oct 4/21	Low-0.00009 High-0.00093 Low-0.00009 High-0.00117	mg/l	
Mercury	March/1/21	D3-<0.00002 D4-<0.00002 D5-<0.00002	“	
Selenium	March/1/21	D3-<0.001 D4-<0.001 D5-<0.001	“	
Sodium	July 6/20	D3-31.6 D4-27.6 D5-15.7	mg/l	
Uranium	March/1/21	D3-0.00193 D4-0.00175 D5-0.00035	mg/l	

Fluoride	March 6/17 Jan 20/20 Jan 23/20	0.86 D5-2.0 D5-2.5	mg/l	
Nitrite	October 5/21	D3-0.1 D4-<0.1 D5-<0.1	“	
Nitrate	October 5/21	D3-1.1 D4-1.9 D5-<0.1	“	

*Only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(Applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

*Note: Municipality is on reduced sampling schedule currently.

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Residential	20	0.00009 – 0.00093	0
Non-Residential	2	0.00023 – 0.00117	0
Distribution	4	0.00015 – 0.00032	0

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	March 5/18	0.02	ug/l	
Aldicarb	March 9/15	0.01	“	
Aldrin + Dieldrin	March 9/15	0.01	“	
Atrazine + N-dealkylated metabolites	March 5/18	0.01	“	
Azinphos-methyl	March 5/18	0.05	ug/l	
Bendiocarb	March 9/15	0.01	“	
Benzene	March 1/21	<0.5	“	
Benzo(a)pyrene	March 5/18	0.004	“	
Bromoxynil	March 5/18	0.33	“	
Carbaryl	March 5/18	0.05	“	
Carbofuran	March 5/18	0.01	“	
Carbon Tetrachloride	March 1/21	<0.2	“	
Chlordane (Total)	March 9/15	0.01	“	
Chlorpyrifos	March 5/18	0.02	“	
Cyanazine	March 9/15	0.03	“	
Diazinon	March 5/18	0.02	“	

Dicamba	March 5/18	0.20	“	
1,2-Dichlorobenzene	March 1/21	<0.5	“	
1,4-Dichlorobenzene	March 1/21	<0.5	“	
Dichlorodiphenyltrichloroethane (DDT) + metabolites	March 9/15	0.01	“	
1,2-Dichloroethane	March 1/21	<0.5	“	
1,1-Dichloroethylene (vinylidene chloride)	March 1/21	<0.5	“	
Dichloromethane	March 1/21	<5	“	
2-4 Dichlorophenol	March 5/18	0.15	“	
2,4-Dichlorophenoxy acetic acid (2,4-D)	March 5/18	0.19	“	
Diclofop-methyl	March 5/18	0.40	“	
Dimethoate	March 5/18	0.03	“	
Dinoseb	March 9/15	0.36	“	
Diquat	March 5/18	1.00	“	
Diuron	March 5/18	0.03	“	
Glyphosate	March 5/18	1.00	“	
Heptachlor + Heptachlor Epoxide	March 9/15	0.01	“	
Haloacetic Acids (Bromoacetic Acid, Chloroacetic Acid, Dichloroacetic Acid, Dibromoacetic Acid, and Trichloroacetic Acid)	October 5/21	5.3	”	
Lindane (Total)	March 9/15	0.01	“	
Malathion	March 5/18	0.02	“	
Methoxychlor	March 5/18	0.03	“	
2-methyl-4-chlorophenoxyacetuc acid	March 5/18	0.00012	mg/l	
Metolachlor	March 9/15	0.06	ug/l	
Metribuzin	March 5/18	0.02	“	
Monochlorobenzene	March 5/18	0.3	“	
Paraquat	March 5/18	1.00	“	
Parathion	March 9/15	0.02	“	
Pentachlorophenol	March 5/18	0.15	“	
Phorate	March 5/18	0.01	“	
Picloram	March 5/18	1.0	“	
Polychlorinated Biphenyls(PCB)	March 5/18	0.04	“	
Prometryne	March 5/18	0.03	“	
Simazine	March 5/18	0.01	“	
THM (NOTE: show latest running annual average)	October 5/21	16.75	ug/l	
Temephos	March 9/15	0.01	“	
Terbufos	March 5/18	0.01	“	
Tetrachloroethylene	March 1/21	<0.5	“	
2,3,4,6-Tetrachlorophenol	March 5/18	0.20	“	
Triallate	March 5/18	0.01	“	
Trichloroethylene	March 5/18	0.44	“	

2,4,6-Trichlorophenol	March 5/18	0.25	“	
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	March 9/15	0.22	“	
Trifluralin	March 5/18	0.02	“	
Vinyl Chloride	March 1/21	<0.2	“	

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

Annual Sampling Results 2021

Year: 2021

Parameter	Ecoli						Total Coliform						HPC						Background		Raw Water Turbidity		Treated Chlorine Free		Treated Turbidity		Distribution Chlorine Free		Distribution Turbidity	
	Raw		Treated		Distribution		Raw		Treated		Distribution		RW-Raw		TW-Treated		DW-Distribution													
	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High
January	0	0	0	0	0	0	0	0	0	0	0	0	0	60	0	10	0	20			0.05	0.11	0.87	1.27	0.05	0.28	0.50	1.26	0.06	0.23
February	0	0	0	0	0	0	0	0	0	0	0	0	0	30	0	10	0	<10			0.06	0.07	0.90	1.25	0.05	0.29	0.58	1.22	0.08	0.27
March	0	0	0	0	0	0	0	3	0	0	0	0	0	10	0	20	0	20			0.07	0.07	0.72	1.42	0.05	0.24	0.68	1.29	0.06	0.27
April	0	0	0	0	0	0	0	0	0	0	0	0	0	20	0	>2000	0	30			0.06	0.08	0.70	1.31	0.05	0.21	0.61	1.24	0.06	0.24
May	0	0	0	0	0	0	0	0	0	0	0	0	0	10	0	20	0	10			0.05	0.06	1.01	1.33	0.05	0.25	0.68	1.17	0.07	0.29
June	0	1	0	0	0	0	0	6	0	0	0	0	0	20	0	10	0	50			0.05	0.06	0.82	1.32	0.04	0.24	0.52	1.21	0.06	0.21
July	0	0	0	0	0	0	0	1	0	0	0	0	0	130	0	10	0	30			0.05	0.10	0.77	1.23	0.04	0.26	0.34	1.02	0.08	0.24
August	0	0	0	0	0	0	0	5	0	0	0	0	0	180	0	200	0	90			0.05	0.08	0.75	1.43	0.05	0.28	0.37	1.22	0.06	0.31
September	0	0	0	0	0	0	0	0	0	0	0	0	0	120	0	430	0	270			0.08	0.11	0.82	1.21	0.08	0.28	0.42	0.99	0.12	0.27
October	0	0	0	0	0	0	0	1	0	0	0	0	0	40	0	20	0	10			0.09	0.11	0.81	1.33	0.04	0.28	0.43	1.12	0.07	0.27
November	0	0	0	0	0	0	0	0	0	0	0	0	0	750	0	360	0	120			0.04	0.06	0.80	1.44	0.05	0.24	0.46	1.29	0.07	0.23
December	0	0	0	0	0	0	0	1	0	0	0	0	0	100	0	10	0	10			0.05	0.08	0.90	1.57	0.05	0.29	0.81	1.45	0.08	0.21
Recap for Year	0	1	0	0	0	0	0	6	0	0	0	0	0	750	0	430	0	>2000	-	-	0.04	0.11	0.70	1.57	0.04	0.29	0.34	1.45	0.06	0.31

Lab Reports

Annual Summary - Distribution System Bacteriological Data

Water Works Name:	Dundalk Water Works
Year:	2021
Serviced Population:	2431
Laboratories Which Performed Analyses:	Lakefield Research Ltd.
	Caduceon Labs

Distribution System

Month	Total Coliform			Fecal Coliform/Escherichia Coli			HPC or MF		
	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"
January	16	16	0	16	16	0	16	16	0
February	16	16	0	16	16	0	16	16	0
March	20	20	0	20	20	0	20	20	0
April	18	18	0	18	18	0	18	18	0
May	20	20	0	20	20	0	20	20	0
June	16	16	0	16	16	0	16	16	0
July	16	16	0	16	16	0	16	16	0
August	20	20	0	20	20	0	20	20	0
September	16	16	0	16	16	0	16	16	0
October	16	16	0	16	16	0	16	16	0
November	20	20	0	20	20	0	20	20	0
December	16	16	0	16	16	0	16	16	0
Total	210	210	0	210	210	0	210	210	0

Input into the Distribution System Bacteriological Data

Water Works Name: Dundalk Water Works
Well No. (If applicable) Well #3
Year: 2021
Serviced Population: 2431
Laboratories Which Performed Analyses: Lakefield Research Ltd.
 Caduceon Labs

Treated Water

Month	Total Coliform			Fecal Coliform/Escherichia Coli			HPC or MF		
	No. of Samples	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"
January	4	4	0	4	4	0	4	4	0
February	4	4	0	4	4	0	4	4	0
March	5	5	0	5	5	0	5	5	0
April	4	4	0	4	4	0	4	4	0
May	5	5	0	5	5	0	5	5	0
June	4	4	0	4	4	0	4	4	0
July	4	4	0	4	4	0	4	4	0
August	5	5	0	5	5	0	5	5	0
September	4	4	0	4	4	0	4	4	0
October	4	4	0	4	4	0	4	4	0
November	5	5	0	5	5	0	5	5	0
December	4	4	0	4	4	0	4	4	0
Total	52	52	0	52	52	0	52	52	0

Input into the Distribution System Bacteriological Data

Water Works Name: Dundalk Water Works
Well No. (If applicable) Well # 4
Year: 2021
Serviced Population: 2431
Laboratories Which Performed Analyses: Lakefield Research Ltd.
 Caduceon Labs

Treated Water

Month	Total Coliform			Fecal Coliform/Escherichia Coli			HPC or MF		
	No. of Samples	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"
January	4	4	0	4	4	0	4	4	0
February	4	4	0	4	4	0	4	4	0
March	5	5	0	5	5	0	5	5	0
April	4	4	0	4	4	0	4	4	0
May	5	5	0	5	5	0	5	5	0
June	4	4	0	4	4	0	4	4	0
July	4	4	0	4	4	0	4	4	0
August	7	7	0	7	7	0	7	7	0
September	4	4	0	4	4	0	4	4	0
October	4	4	0	4	4	0	4	4	0
November	5	5	0	5	5	0	5	5	0
December	4	4	0	4	4	0	4	4	0
Total	54	54	0	54	54	0	54	54	0

Input into the Distribution System Bacteriological Data

Water Works Name: Dundalk Water Works
Well No. (If applicable) Well # 5
Year: 2021
Serviced Population: 2431
Laboratories Which Performed Analyses: Lakefield Research Ltd.
 Caduceon Labs

Treated Water

Month	Total Coliform			Fecal Coliform/Escherichia Coli			HPC or MF		
	No. of Samples	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"
January	4	4	0	4	4	0	4	4	0
February	5	5	0	5	5	0	5	5	0
March	5	5	0	5	5	0	5	5	0
April	4	4	0	4	4	0	4	4	0
May	5	5	0	5	5	0	5	5	0
June	4	4	0	4	4	0	4	4	0
July	4	4	0	4	4	0	4	4	0
August	5	5	0	5	5	0	5	5	0
September	4	4	0	4	4	0	4	4	0
October	4	4	0	4	4	0	4	4	0
November	5	5	0	5	5	0	5	5	0
December	4	4	0	4	4	0	4	4	0
Total	53	53	0	53	53	0	53	53	0

**Annual Summary - Raw Water (A Separate Sheet Should Be Completed For Each Raw
Water Input To The Treatment Works) Bacteriological Data**

Water Works Name:	Dundalk Water Works
Well No. (If applicable)	Well # 3
Year:	2021
Serviced Population:	2431
Laboratories Which Performed Analyses:	Lakefield Research Ltd.
	Caduceon Labs

Raw Water

Month	Total Coliform			Fecal Coliform/Escherichia Coli		
	No. of Samples	No. of Samples 0 Organisms/100 ml	No. of Samples > 0 Organisms/100ml	No. of Samples Collected	No. of Samples 0 Org./100 ml	No. of Samples > 0 Organisms/100ml
January	4	4	0	4	4	0
February	4	4	0	4	4	0
March	5	4	1	5	5	0
April	4	4	0	4	4	0
May	5	5	0	5	5	0
June	4	3	1	4	3	1
July	4	2	2	4	4	0
August	5	4	1	5	5	0
September	4	4	0	4	4	0
October	4	3	1	4	4	0
November	5	5	0	5	5	0
December	4	4	0	4	4	0
Total	52	46	6	52	51	1

**Annual Summary - Raw Water (A Separate Sheet Should Be Completed For Each Raw
Water Input To The Treatment Works) Bacteriological Data**

Water Works Name:	Dundalk Water Works
Well No. (If applicable)	Well # 4
Year:	2021
Serviced Population:	2431
Laboratories Which Performed Analyses:	Lakefield Research Ltd.
	Caduceon Labs

Raw Water

Month	Total Coliform			Fecal Coliform/Escherichia Coli		
	No. of Samples	No. of Samples 0 Organisms/100 ml	No. of Samples > 0 Organisms/100ml	No. of Samples Collected	No. of Samples 0 Org./100 ml	No. of Samples > 0 Organisms/100ml
January	4	4	0	4	4	0
February	4	4	0	4	4	0
March	5	5	0	5	5	0
April	4	4	0	4	4	0
May	5	5	0	5	5	0
June	4	4	0	4	4	0
July	4	4	0	4	4	0
August	5	5	0	5	5	0
September	4	4	0	4	4	0
October	4	4	0	4	4	0
November	5	5	0	5	5	0
December	4	3	1	4	4	0
Total	52	51	1	52	52	0

**Annual Summary - Raw Water (A Separate Sheet Should Be Completed For Each Raw
Water Input To The Treatment Works) Bacteriological Data**

Water Works Name:	Dundalk Water Works
Well No. (If applicable)	Well # 5
Year:	2021
Serviced Population:	2431
Laboratories Which Performed Analyses:	Lakefield Research Ltd.
	Caduceon Labs

Raw Water

Month	Total Coliform			Fecal Coliform/Escherichia Coli		
	No. of Samples	No. of Samples 0 Organisms/100 ml	No. of Samples > 0 Organisms/100ml	No. of Samples Collected	No. of Samples 0 Org./100 ml	No. of Samples > 0 Organisms/100ml
January	4	4	0	4	4	0
February	4	4	0	4	4	0
March	5	5	0	5	5	0
April	4	4	0	4	4	0
May	5	5	0	5	5	0
June	4	4	0	4	4	0
July	4	4	0	4	4	0
August	5	5	0	5	5	0
September	4	4	0	4	4	0
October	4	4	0	4	4	0
November	5	5	0	5	5	0
December	4	4	0	4	4	0
Total	52	52	0	52	52	0

Input into the Distribution System Bacteriological Data

Water Works Name: Dundalk Water Works
Well No. (If applicable): Well # 3
Year: 2021
Serviced Population: 2431
Design Capacity: 1636 m³/Day
Laboratories Which Performed Analyses: Lakefield Research Ltd.
 Caduceon Labs

Treated Water

Month	Treated Water Flow			Influent Wastewater Monthly Total m ³	Treated Water Turbidity			Treated Disinfectant		Dist. System Disinfectant	
	Average m ³	Maximum Day m ³	Monthly Total m ³		No. of Samples Collected	No. of Samples > 1 NTU	Average Turbidity NTU	No. of Treated Samples Collected	Average Free Residual (mg/L)	No. of Dist. Samples	No. of Samples without Required Chlorine Residual
January	219	297	6309	32176	31	0	0.21	31	1.08	31	0
February	201	282	5631	20911	28	0	0.23	28	1.10	28	0
March	200	275	6196	57667	31	0	0.2	31	1.28	31	0
April	200	239	5986	36273	30	0	0.18	30	1.12	30	0
May	200	230	6192	32544	31	0	0.20	31	1.12	31	0
June	201	277	6035	20557	30	0	0.21	30	1.12	30	0
July	200	248	6208	40489	31	0	0.22	31	0.98	31	0
August	199	274	6177	25646	31	0	0.22	31	1.09	31	0
September	216	335	6028	39590	30	0	0.24	30	1.04	30	0
October	201	272	6239	40783	31	0	0.21	31	1.10	31	0
November	217	330	5964	45034	30	0	0.21	30	1.22	30	0
December	216	358	6179	55049	31	0	0.23	31	1.34	31	0
Total			73144	446719	365	0		365		365	0
Average	205.833						0.21		1.13		
Maximum		358.000									

Disinfectant Compound Used:
 (eg. Chlorine Gas, NaOCl, Etc.) **NaOCl**

Form of Residual Displayed on Above Table:
 (I. E. Free, Combined, or Total) **Free**

Distribution System Target Residual (mg./L): **> 0.2 Free**

Recap for Month
 Recap for Month

Input into the Distribution System Bacteriological Data

Water Works Name: Dundalk Water Works
Well No. (If applicable) Well # 4
Year: 2021
Serviced Population: 2431
Design Capacity: 1636 m³/Day
Laboratories Which Performed Analyses: Lakefield Research Ltd.
 Caduceon Labs

Treated Water

Month	Treated Water Flow			Influent Wastewater Monthly Total m3	Treated Water Turbidity			Treated Disinfectant		Dist. System Disinfectant	
	Average m3	Maximum Day m3	Monthly Total m3		No. of Samples Collected	No. of Samples > 1 NTU	Average Turbidity NTU	No. of Treated Samples Collected	Average Free Residual (mg/L)	No. of Dist. Samples Collected	No. of Samples without Required Chlorine Residual
January	203	512	6277	32176	31	0	0.08	31	1.16	31	0
February	225	458	6291	20911	28	0	0.09	28	1.07	28	0
March	211	272	6556	57667	31	0	0.08	31	1.08	31	0
April	185	257	5553	36273	30	0	0.08	30	1.15	30	0
May	228	450	7055	32544	31	0	0.08	31	1.15	31	0
June	321	507	9618	20577	30	0	0.07	30	1.10	30	0
July	217	296	6727	40489	31	0	0.07	31	1.04	31	0
August	176	304	5446	25646	31	0	0.07	31	1.00	31	0
September	198	255	5953	39590	30	0	0.10	30	0.97	30	0
October	224	441	6931	40783	31	0	0.08	31	0.93	31	0
November	244	452	7348	45034	30	0	0.08	30	0.99	30	0
December	304	501	9502	55049	31	0	0.08	31	1.11	31	0
Total			83257	446739	365	0		365		365	0
Average	228.000						0.08		1.06		
Maximum		512.000									

Disinfectant Compound Used:
 (eg. Chlorine Gas, NaOCl, Etc.) **NaOCl**

Form of Residual Displayed on Above Table:
 (I. E. Free, Combined, or Total) **Free**

Distribution System Target Residual (mg./L): **> 0.2 Free**

Water Consumption Report
 Recap for Month

Input into the Distribution System Bacteriological Data

Water Works Name: Dundalk Water Works
Well No. (If applicable) Well # 5
Year: 2021
Serviced Population: 2431
Design Capacity: 1636 m³/Day
Laboratories Which Performed Analyses: Lakefield Research Ltd.
 Caduceon Labs

Treated Water

Month	Treated Water Flow			Influent Wastewater Monthly Total m ³	Treated Water Turbidity			Treated Disinfectant		Dist. System Disinfectant	
	Average m ³	Maximum Day m ³	Monthly Total m ³		No. of Samples Collected	No. of Samples > 1 NTU	Average Turbidity NTU	No. of Treated Samples Collected	Average Free Residual (mg/L)	No. of Dist. Samples Collected	No. of Samples without Required Chlorine Residual
January	221	414	6912	32176	31	0	0.09	31	1.07	31	0
February	189	294	5283	20911	28	0	0.09	28	0.98	28	0
March	206	381	6391	57667	31	0	0.09	31	0.99	31	0
April	206	356	6188	36273	30	0	0.08	30	1.12	30	0
May	203	258	6278	32544	31	0	0.08	31	1.16	31	0
June	213	374	6393	20577	30	0	0.07	30	1.04	30	0
July	205	261	6369	40489	31	0	0.08	31	1.00	31	0
August	276	548	8556	25646	31	0	0.07	31	0.94	31	0
September	195	320	5967	39590	30	0	0.10	30	0.95	30	0
October	211	527	6535	40783	31	0	0.09	31	0.99	31	0
November	196	213	6023	45034	30	0	0.09	30	1.09	30	0
December	202	381	6389	55049	31	0	0.09	31	1.16	31	0
Total			77284	446739	365	0		365		365	0
Average	210.250						0.09		1.04		
Maximum		548.000									

Disinfectant Compound Used:
 (eg. Chlorine Gas, NaOCl, Etc.) **NaOCl**

Form of Residual Displayed on Above Table:
 (I. E. Free, Combined, or Total) **Free**

Distribution System Target Residual (mg./L): **> 0.2 Free**

Water Consumption Report
 Recap for Month

Annual Report - Fluoride, Nitrite, Nitrate, and Colour

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name: Dundalk Water Works
Well No. (If applicable) Well # 3
Year: 2021
Serviced Population: 2431
Design Capacity: 1636 m³/Day
Laboratories Which Performed Analyses: Lakefield Research Ltd.
 Caduceon Labs

Month	Treated Water Fluoride			Treated Water Nitrite			Treated Water Nitrate			Colour	
	No. of Samples Collected	Average Residual (mg/L)	Maximum Residual (mg/L)	No. of Samples Collected	Average Nitrite (mg/L)	Maximum Nitrite (mg/L)	No. of Samples Collected	Average Nitrate (mg/L)	Maximum Nitrate (mg/L)	Average Raw (TCU)	Average Treated (TCU)
January				1	<0.1	<0.1	1	1	1		
February											
March											
April				1	<0.1	<0.1	1	1.1	1.1		
May											
June											
July				1	<0.1	<0.1	1	0.9	0.9		
August											
September											
October				1	0.1	0.1	1	1.1	1.1		
November											
December											
Total	0			4			4				
Average		#DIV/0!			0.025			1.025			
Maximum			0.000			0.100			1.100		
ODWO			1.5		0.1	1		1	10		

Where Nitrate and Nitrite are present, the total of the two should not exceed 10mg/L.

Fluoride levels above 1.5mg/L should be reported to the Medical Officer of Health.

Annual Report - Flouride, Nitrite, Nitrate, and Colour

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name: Dundalk Water Works
Well No. (If applicable) Well # 4
Year: 2021
Serviced Population: 2431
Design Capacity: 1636 m³/Day
Laboratories Which Performed Analyses: Lakefield Research Ltd.
 Caduceon Labs

Month	Treated Water Fluoride			Treated Water Nitrite			Treated Water Nitrate			Colour	
	No. of Samples Collected	Average Residual (mg/L)	Maximum Residual (mg/L)	No. of Samples Collected	Average Nitrite (mg/L)	Maximum Nitrite (mg/L)	No. of Samples Collected	Average Nitrate (mg/L)	Maximum Nitrate (mg/L)	Average Raw (TCU)	Average Treated (TCU)
January				1	<0.1	<0.1	1	1.7	1.7		
February											
March											
April				1	<0.1	<0.1	1	2.0	2.0		
May											
June											
July				1	<0.1	<0.1	1	1.8	1.8		
August											
September											
October				1	<0.1	<0.1	1	1.9	1.9		
November											
December											
Total	0			4			4				
Average		#DIV/0!			0.000			1.850			
Maximum			0			0			2		
ODWO			1.5		0.1	1		1	10		

Where Nitrate and Nitrite are present, the total of the two should not exceed 10mg/L.

Flouride levels above 1.5mg/L should be reported to the Medical Officer of Health.

Annual Report - Flouride, Nitrite, Nitrate, and Colour

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name: Dundalk Water Works
Well No. (If applicable) Well # 5
Year: 2021
Serviced Population: 2431
Design Capacity: 1636 m³/Day
Laboratories Which Performed Analyses: Lakefield Research Ltd.
 Caduceon Labs

Month	Treated Water Fluoride			Treated Water Nitrite			Treated Water Nitrate			Colour	
	No. of Samples Collected	Average Residual (mg/L)	Maximum Residual (mg/L)	No. of Samples Collected	Average Nitrite (mg/L)	Maximum Nitrite (mg/L)	No. of Samples Collected	Average Nitrate (mg/L)	Maximum Nitrate (mg/L)	Average Raw (TCU)	Average Treated (TCU)
January				1	<0.1	<0.1	1	<0.1	<0.1		
February											
March											
April				1	<0.1	<0.1	1	<0.1	<0.1		
May											
June											
July				1	<0.1	<0.1	1	<0.1	<0.1		
August											
September											
October				1	<0.1	<0.1	1	<0.1	<0.1		
November											
December											
Total	0			4			4				
Average		0.000			0.000			0.000			
Maximum			0			0			0		
ODWO			1.5		0.1	1		1	10		

Where Nitrate and Nitrite are present, the total of the two should not exceed 10mg/L.

Flouride levels above 1.5mg/L should be reported to the Medical Officer of Health.

Annual Data Summary - Treated Water Volatile Organic & Inorganic Data

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name: Dundalk Water Works
Well No. (If applicable): Well #3
Year: 2021
Serviced Population: 2431
Design Capacity: 1636 m³/Day
Laboratories Which Performed Analyses: Lakefield Research Ltd.
Caduceon Labs

Treated Water (except for Lead, THM's and HAA's which should be sampled for in the distribution system)

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested	ODWO MAC/IMAC/AO (ug/L)
TABLE B VOLATILE ORGANICS	Date	Results (ug/L)	Date (DD/MM/YY)	Results (ug/L)	Date (DD/MM/YY)	Results (ug/L)	Date (DD/MM/YY)	Results (ug/L)			
Benzene	1-Mar-21	<0.5	5-Mar-12	0.32	9-Mar-15	0.32	5-Mar-18	0.32	3 years	1-Mar-21	1
Carbon Tetrachloride	1-Mar-21	<0.2	5-Mar-12	0.16	9-Mar-15	0.16	5-Mar-18	0.16	3 years	1-Mar-21	2
1, 2 - Dichlorobenzene	1-Mar-21	<0.5	5-Mar-12	0.41	9-Mar-15	0.41	5-Mar-18	0.41	3 years	1-Mar-21	200
1, 4 - Dichlorobenzene	1-Mar-21	<0.5	5-Mar-12	0.36	9-Mar-15	0.36	5-Mar-18	0.36	3 years	1-Mar-21	5
1, 2 - Dichloroethane	1-Mar-21	<0.5	5-Mar-12	0.35	9-Mar-15	0.35	5-Mar-18	0.35	3 years	1-Mar-21	5
1, 1 - Dichloroethylene	1-Mar-21	<0.5	5-Mar-12	0.33	9-Mar-15	0.33	5-Mar-18	0.33	3 years	1-Mar-21	14
Dichloromethane	1-Mar-21	<5	5-Mar-12	0.35	9-Mar-15	0.35	5-Mar-18	0.35	3 years	1-Mar-21	50
Ethylbenzene	1-Nov-00	<0.0024							Aesthetic Objective	1-Nov-00	140
Monochlorobenzene	1-Mar-21	<0.5	5-Mar-12	0.3	9-Mar-15	0.3	5-Mar-18	0.3	3 years	1-Mar-21	80
Tetrachloroethylene	1-Mar-21	<0.5	5-Mar-12	0.35	9-Mar-15	0.35	5-Mar-18	0.35	3 years	1-Mar-21	10
TolueneTrichloroethylene	1-Mar-21	<0.5	5-Mar-12	0.44	9-Mar-15	0.44	5-Mar-18	0.44	3 years	1-Mar-21	60
Vinyl Chloride	1-Mar-21	<0.2	5-Mar-12	0.17	9-Mar-15	0.17	5-Mar-18	0.17	3 years	1-Mar-21	1
Xylene	1-Nov-00	0.005							Aesthetic Objective	1-Nov-00	90
TABLE C - INORGANICS											
Arsenic	1-Mar-21	0.00120	5-Mar-12	2.60	9-Mar-15	2.2	5-Mar-18	2.6	3 years	1-Mar-21	10
Barium	1-Mar-21	0.10500	5-Mar-12	122	9-Mar-15	116	5-Mar-18	126	3 years	1-Mar-21	1000
Boron	1-Mar-21	0.05400	5-Mar-12	48	9-Mar-15	57.6	5-Mar-18	55	3 years	1-Mar-21	5000
Cadmium	1-Mar-21	<0.000015	5-Mar-12	0.003	9-Mar-15	0.005	5-Mar-18	0.003	3 years	1-Mar-21	5
Chromium	1-Mar-21	<0.002	5-Mar-12	0.50	9-Mar-15	0.03	5-Mar-18	0.21	3 years	1-Mar-21	50
Copper	1-Nov-00	<0.005							Aesthetic Objective	1-Nov-00	1000
Iron	18-Jul-12	10	10-Sep-12	8	20-Dec-12	10	13-Jan-13	15	Aesthetic Objective	13-Jan-13	300
Lead	17-Mar-16	3.68	15-Sep-16	0.33	14-Mar-17	0.43	20-Sep-17	1.33	3 years	20-Sep-17	10
Manganese	12-Apr-08	7.0	20-Dec-12	6	13-Jan-13	5.6			Aesthetic Objective	13-Jan-13	20
Mercury	1-Mar-21	<0.00002	5-Mar-12	0.02	9-Mar-15	0.01	5-Mar-18	0.01	3 years	1-Mar-21	1
Selenium	1-Mar-21	<0.001	5-Mar-12	1.00	9-Mar-15	1	5-Mar-18	0.07	3 years	1-Mar-21	50
Uranium	1-Mar-21	0.001930	5-Mar-12	2.13	9-Mar-15	2.1	5-Mar-18	1.53	3 years	1-Mar-21	20
Zinc	1-Jan-01	<0.01							Aesthetic Objective	23-Jan-01	5000

Annual Data Summary - Treated Water Volatile Organic & Inorganic Data

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name: Dundalk Water Works
Well No. (If applicable): Well # 4
Year: 2021
Serviced Population: 2431
Design Capacity: 1636 m³/Day
Laboratories Which Performed Analyses: Lakefield Research Ltd.
 Caduceon Labs

Treated Water (except for lead, THM's and HAA's which should be sampled for in the distribution system)

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested (year)	ODWO MAC/IMAC/AO (ug/L)
TABLE B VOLATILE ORGANICS	Date	Results (ug/L)	Date (DD/MM/YY)	Results (ug/L)	Date (DD/MM/YY)	Results (ug/L)	Date (DD/MM/YY)	Results (ug/L)			
Benzene	1-Mar-21	<0.5	5-Mar-12	0.32	9-Mar-15	0.32	5-Mar-18	0.32	3 years	1-Mar-21	1
Carbon Tetrachloride	1-Mar-21	<0.2	5-Mar-12	0.16	9-Mar-15	0.16	5-Mar-18	0.16	3 years	1-Mar-21	2
1, 2 - Dichlorobenzene	1-Mar-21	<0.5	5-Mar-12	0.41	9-Mar-15	0.41	5-Mar-18	0.41	3 years	1-Mar-21	200
1, 4 - Dichlorobenzene	1-Mar-21	<0.5	5-Mar-12	0.36	9-Mar-15	0.36	5-Mar-18	0.36	3 years	1-Mar-21	5
1, 2 - Dichloroethane	1-Mar-21	<0.5	5-Mar-12	0.43	9-Mar-15	0.35	5-Mar-18	0.35	3 years	1-Mar-21	5
1, 1 - Dichloroethylene	1-Mar-21	<0.5	5-Mar-12	0.33	9-Mar-15	0.33	5-Mar-18	0.33	3 years	1-Mar-21	14
Dichloromethane	1-Mar-21	<5	5-Mar-12	0.35	9-Mar-15	0.35	5-Mar-18	0.35	3 years	1-Mar-21	50
Ethylbenzene	22-Dec-04	0.47	1-Jun-02	<0.0005					Aesthetic Objective	22-Dec-04	140
Monochlorobenzene	1-Mar-21	<0.5	5-Mar-12	0.3	9-Mar-15	0.3	5-Mar-18	0.3	3 years	1-Mar-21	80
Tetrachloroethylene	1-Mar-21	<0.5	5-Mar-12	0.35	9-Mar-15	0.35	5-Mar-18	0.35	3 years	1-Mar-21	10
TolueneTrichloroethylene	1-Mar-21	<0.5	5-Mar-12	0.44	9-Mar-15	0.44	5-Mar-18	0.44	3 years	1-Mar-21	60
Vinyl Chloride	1-Mar-21	<0.2	5-Mar-12	0.17	9-Mar-15	0.17	5-Mar-18	0.17	3 years	1-Mar-21	1
Xylene	1-Jun-02	<0.0015							Aesthetic Objective	1-Jun-02	90
TABLE C - INORGANICS											
Arsenic	1-Mar-21	0.00030	5-Mar-12	0.70	9-Mar-15	0.6	5-Mar-18	0.5	3 years	1-Mar-21	10
Barium	1-Mar-21	0.09600	5-Mar-12	96.9	9-Mar-15	103	5-Mar-18	113	3 years	1-Mar-21	1000
Boron	1-Mar-21	0.04000	5-Mar-12	32	9-Mar-15	44.7	5-Mar-18	40	3 years	1-Mar-21	5000
Cadmium	1-Mar-21	<0.000015	3.5/12	0.003	9-Mar-15	0.007	5-Mar-18	0.006	3 years	1-Mar-21	5
Chromium	1-Mar-21	<0.002	5-Mar-12	0.50	9-Mar-15	0.03	5-Mar-18	0.14	3 years	1-Mar-21	50
Copper	22-Dec-04	1.2	1-Jun-02	<0.001					Aesthetic Objective	22-Dec-04	1000
Iron	22-Dec-04	<10							Aesthetic Objective	22-Dec-04	300
Lead	17-Mar-16	4.72	14-Sep-16	1.34	14-Mar-17	0.57	20-Sep-17	0.77	3 years	20-Sep-17	10
Manganese	22-Dec-04	22							Aesthetic Objective	22-Dec-04	20
Mercury	1-Mar-21	<0.00002	5-Mar-12	0.02	9-Mar-15	0.01	5-Mar-18	0.01	3 years	1-Mar-21	1
Selenium	1-Mar-21	<0.001	5-Mar-12	1.00	9-Mar-15	1	5-Mar-18	0.26	3 years	1-Mar-21	50
Uranium	1-Mar-21	0.001750	5-Mar-12	1.76	9-Mar-15	1.39	5-Mar-18	1.52	3 years	1-Mar-21	20
Zinc	22-Dec-04	3	1-Jun-02	0.006					Aesthetic Objective	22-Dec-04	5000

Annual Data Summary - Parameters Not Listed in the Minimum Sampling Program

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name: Dundalk Water Works

Well No. (If applicable)	Well # 3
--------------------------	----------

Year: 2021

Year:	2021
Serviced Population:	2431

Design Capacity:	1636	m ³ /Day
------------------	------	---------------------

Laboratories Which Performed Analyses:	Lakefield Research Ltd.
--	-------------------------

Caduceon Labs

Treated Water (Except for Lead Which Should Be Sampled For in the Distribution System)

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested	ODWO MAC/IMAC/AO (mg/L)
	Date	Results (mg/L)	Date (DD/MMM/YY)	Results (mg/L)	Date (DD/MMM/YY)	Results (mg/L)	Date (DD/MMM/YY)	Results (mg/L)			
OTHER PARAMETERS (List as Required)		=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
Hardness	12-Apr-08	268	20-Dec-12	288	13-Jan-13	281			Operational Objective	13-Jan-13	80 - 100
Sodium	12-Jul-21	30	9-Mar-20	29.5	6-Jul-20	31.6	1-Mar-21	31.6	Annually	1-Mar-21	20
Flouride	6-Jun-10	0.57	5-Mar-12	0.06	6-Mar-17	0.86			5 years	6-Mar-17	1.5
Hydrogen Sulphide									Aesthetic Objective	23-Jan-01	0.05
Alkalinity as Ca CO3	20-Dec-12	264	13-Jan-13	251					Operational Objective	13-Jan-13	30 - 500
Chloride	14-Jan-19	45	13-Jan-20	49.4	12-Jul-21	44.6	9-Jan-18	36	Operational Objective	12-Jul-21	250
Sulphate	20-Dec-12	17	13-Jan-13	17					Aesthetic Objective	13-Jan-13	500
Organic Nitrogen 6	20-Dec-12	0.05	13-Jan-13	0.14					Operational Objective	13-Jan-13	0.15
Dissolved Organic C	12-Apr-08	0.8							Aesthetic Objective	12-Apr-08	5
Nitriotriacetic Acid	23-Jan-01	<0.3								23-Jan-01	0.4
Total Dissolved Solids	12-Apr-08	334	13-Jan-13	409					Aesthetic Objective	13-Jan-13	500
Total Cynanide	10-Jan-01	0.2								23-Jan-01	0.2
Benzo (a) Pyreneene	1-Mar-21	<0.006	5-Mar-12	0.004	11-Mar-15	0.004	5-Mar-18	0.004	3 years	1-Mar-21	0.01 ug/l
N-Nitrosodimethylamine	23-Jan-01	<.000007								23-Jan-01	0.000009
Ammonia	11-Apr-16	0.71	10-Oct-16	0.7	11-Apr-17	0.35	16-Oct-17	0.3		16-Oct-17	
Nitrates	4-Jan-21	1	6-Apr-21	1.1	5-Jul-21	0.9	5-Oct-21	1.1	Quarterly	5-Oct-21	10
Nitrites	4-Jan-21	<0.1	6-Apr-21	<0.1	5-Jul-21	<0.1	5-Oct-21	0.1	Quarterly	5-Oct-21	1
Pesticides & PCB's	1-Nov-00	0.001	5-Mar-12	0.04	9-Mar-15	0.04	1-Mar-21	<0.05		1-Mar-21	3
pH	20-Dec-12	8.01	13-Jan-13	7.98	31-Dec-15	7.58			Operational Objective	31-Dec-15	6.5 - 8.5
Radionuclides-Gross Alpha	4-Mar-19	0.13	23-Mar-20	<0.10	1-Mar-21	<0.10	5-Mar-18	0.14	Annually	1-Mar-21	0.1 bq/l
Radionuclides-Gross Beta	4-Mar-19	<0.10	23-Mar-20	<0.10	1-Mar-21	0.15	5-Mar-18	0.17	Annually	1-Mar-21	0.5 bq/l
Radionuclides-Tritium	4-Mar-19	<15	23-Mar-20	<15	1-Mar-21	<15	5-Mar-18	0	Annually	1-Mar-21	7000 bq/l
True Colour (TCU)									Aesthetic Objective	23-Jan-01	5 TCU

Annual Data Summary - Parameters Not Listed in the Minimum Sampling Program

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name: Dundalk Water Works

Water Works Name:	Dundalk Water Works
Well No. (If applicable)	Well # 4

Year:	2021
-------	------

Year:	2021
Serviced Population:	2431

Design Capacity:	1636	m ³ /Day
------------------	------	---------------------

Laboratories Which Performed Analyses:	Lakefield Research Ltd.
---	-------------------------

Laboratories Which Performed Analyses: Caduceon Labs

Treated Water (Except for Lead Which Should Be Sampled For in the Distribution System)

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested	ODWO MAC/IMAC/AO (mg/L)
	Date	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)			
OTHER PARAMETERS (List as Required)		<div> <div> <div></div> <div></div> </div> <div> <div></div> <div></div> </div> </div>	<div> <div> <div></div> <div></div> </div> <div> <div></div> <div></div> </div> </div>	<div> <div> <div></div> <div></div> </div> <div> <div></div> <div></div> </div> </div>	<div> <div> <div></div> <div></div> </div> <div> <div></div> <div></div> </div> </div>	<div> <div> <div></div> <div></div> </div> <div> <div></div> <div></div> </div> </div>	<div> <div> <div></div> <div></div> </div> <div> <div></div> <div></div> </div> </div>	<div> <div> <div></div> <div></div> </div> <div> <div></div> <div></div> </div> </div>	<div> <div> <div></div> <div></div> </div> <div> <div></div> <div></div> </div> </div>	<div> <div> <div></div> <div></div> </div> <div> <div></div> <div></div> </div> </div>	<div> <div> <div></div> <div></div> </div> <div> <div></div> <div></div> </div> </div>
Hardness	22-Dec-04	236							Operational Objective	22-Dec-04	80 - 100
Sodium	12-Jul-21	28.5	9-Mar-20	30.2	6-Jul-20	27.6	1-Mar-21	30.2	Annually	1-Mar-21	20
Flouride	6-Jul-10	1.2	1-Mar-11	1.19	5-Mar-12	0.71	6-Mar-17	0.75	5 years	6-Mar-17	1.5
Hydrogen Sulphide									Aesthetic Objective	12/22/04	0.05
Alkalinity as Ca CO ₃	22-Dec-04	247							Operational Objective	12/22/04	30 - 500
Chloride	14-Jan-19	46	13-Jan-20	54.7	12-Jul-21	43.1	9-Jan-18	43	Operational Objective	12-Jul-21	250
Sulphate	22-Dec-04	9.8							Aesthetic Objective	22-Dec-04	500
Organic Nitrogen 6	22-Dec-04	0.05							Operational Objective	22-Dec-04	0.15
Dissolved Organic C	22-Dec-04	0.2							Aesthetic Objective	22-Dec-04	5
Nitrilotriacetic Acid	22-Dec-04	0.03								22-Dec-04	0.4
Total Dissolved Solids	22-Dec-04	303							Aesthetic Objective	22-Dec-04	500
Total Cyanide	22-Dec-04	0.2								22-Dec-04	0.2
Benzo (a) Pyrenene	1-Mar-21	<0.006	5-Mar-12	0.32	11-Mar-15	0.004	5-Mar-18	0.004	3 years	1-Mar-21	0.01 ug/l
N-Nitrosodimethylamine	22-Dec-04	0.0012								22-Dec-04	0.00009
Ammonia	22-Dec-04	0.06								22-Dec-04	
Nitrates	4-Jan-21	1.700	6-Apr-21	2.000	5-Jul-21	1.8	5-Oct-21	1.9	Quarterly	5-Oct-21	10
Nitrites	4-Jan-21	<0.1	6-Apr-21	<0.1	5-Jul-21	<0.1	5-Oct-21	<0.1	Quarterly	5-Oct-21	1
Pesticides & PCB's	3-Feb-09	0.04	5-Mar-12	0.004	9-Mar-15	0.04	1-Mar-21	<0.05		1-Mar-21	3
pH	31-Dec-15	7.5							Operational Objective	31-Dec-15	6.5 - 8.5
Radionuclides-Gross Alpha	4-Mar-19	0.12	23-Mar-20	<0.10	1-Mar-21	0.12	5-Mar-18	0.17	Annually	1-Mar-21	0.1 bq/l
Radionuclides-Gross Beta	4-Mar-19	<0.10	23-Mar-20	<0.10	1-Mar-21	0.11	5-Mar-18	<0.10	Annually	1-Mar-21	0.5 bq/l
Radionuclides-Tritium	4-Mar-19	<15	23-Mar-20	<15	1-Mar-21	<15	5-Mar-18	<15	Annually	1-Mar-21	7000 bq/l
True Colour (TCU)	22-Dec-04	3							Aesthetic Objective	22-Dec-04	5 TCU

Annual Data Summary - Parameters Not Listed in the Minimum Sampling Program

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name: Dundalk Water Works

Well No. (If applicable)	Well # 5
--------------------------	----------

Year:	2021
-------	------

Serviced Population:	2431
----------------------	------

Design Capacity:	1636	m ³ /Day
-------------------------	------	---------------------

Laboratories Which Performed Analyses:	Lakefield Research Ltd.
--	-------------------------

Examination Method: Examination

Treated Water (Except for Lead Which Should Be Sampled For in the Distribution System)

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested	ODWO MAC/IMAC/AOC (mg/L)
	Date	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)			
OTHER PARAMETERS (List as Required)		=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
Hardness					17-Oct-16	265000	27-Jan-17	231000	Operational Objective	27-Jan-17	80000-100000
Sodium	9-Mar-20	16.3	6-Jul-20	15.7	1-Mar-21	17.2	12-Jul-21	15.9	Annually	1-Mar-21	20
Flouride	20-Jan-20	2	23-Jan-20	2.5	17-Oct-16	1.69	27-Jan-17	1.75	5 years	27-Jan-17	1.5
Hydrogen Sulphide					17-Oct-16	0.22	27-Jan-17	<0.21	Aesthetic Objective	27-Jan-17	0.05
Alkalinity as Ca CO ₃					17-Oct-16	248	27-Jan-17	243	Operational Objective	27-Jan-17	30 - 500
Chloride	13-Jan-20	22.7	12-Jul-21	18.9	17-Oct-16	16.5	27-Jan-17	15.2	Operational Objective	12-Jul-21	250
Sulphate					17-Oct-16	0.021	27-Jan-17	<0.020	Aesthetic Objective	27-Jan-17	500
Organic Nitrogen 6							27-Jan-17	<0.15	Operational Objective	27-Jan-17	0.15
Dissolved Organic C					17-Oct-16	1.7	27-Jan-17	1.4	Aesthetic Objective	27-Jan-17	5
Nitritotriacetic Acid					17-Oct-16	<0.20	27-Jan-17	<0.20		27-Jan-17	0.4
Total Dissolved Solids					17-Oct-16	281	27-Jan-17	279	Aesthetic Objective	27-Jan-17	500
Total Cyanide					17-Oct-16	<0.0020	27-Jan-17	<0.0020		27-Jan-17	0.2
Benzo (a) Pyrenene			1-Mar-21	<0.006	17-Oct-16	<0.010	27-Jan-17	<0.010	3 years	1-Mar-21	0.01 ug/l
N-Nitrosodimethylamine					17-Oct-16	0.71	27-Jan-17	1.8		27-Jan-17	9
Ammonia					17-Oct-16	0.051	27-Jan-17	0.056		27-Jan-17	
Nitrates	6-Apr-21	<0.1	5-Jul-21	<0.1	5-Oct-21	<0.1	4-Jan-21	<0.1	Quarterly	5-Oct-21	10
Nitrites	6-Apr-21	<0.1	5-Jul-21	<0.1	5-Oct-21	<0.1	4-Jan-21	<0.1	Quarterly	5-Oct-21	1
Pesticides & PCB's							1-Mar-21	<0.05		1-Mar-21	3
pH					17-Oct-16	8	27-Jan-17	7.4	Operational Objective	0-Jan-00	6.5 - 8.5
Radionuclides-Gross Alpha	23-Mar-20	<0.10	1-Mar-21	0.11			27-Jan-17	0.14	Annually	1-Mar-21	0.5 bq/l
Radionuclides-Gross Beta	23-Mar-20	<0.10	1-Mar-21	0.1			27-Jan-17	<0.10	Annually	1-Mar-21	1.0 bq/l
Radionuclides-Tritium	23-Mar-20	<15	1-Mar-21	<15			27-Jan-17	<15	Annually	1-Mar-21	7000 bq/l
True Colour (TCU)					17-Oct-16	<2.0	27-Jan-17	<2.0	Aesthetic Objective	27-Jan-17	5 TCU

Annual Data Summary - Distribution System Volatile Organic Compounds Data

Total Haloacetic (HAA) Annual Average Results

Quarter	Quarter Dates	Sample 1	Sample 2	Sample 3	Sample 4	Quarterly Average (ug/L)	MAC (maximum allowable concentration)
1-2020	04-Jan-21	5.3	5.3			5.3	
2-2020	06-Apr-21	5.3	5.3			5.3	
3-2020	05-Jul-21	5.3	5.3			5.3	
4-2020	05-Oct-21	5.3	5.3			5.3	
(RAA) Running Annual Average						5.3	80 ug/L

Total Trihalomethane (THM) Annual Average Results

Quarter	Quarter Dates	Sample 1	Sample 2	Sample 3	Sample 4	Quarterly Average (ug/L)	MAC (Maximum allowable concentration)
1-2020	04-Jan-21	22	12			17	
2-2020	06-Apr-21	23	11			17	
3-2020	05-Jul-21	6	25			15.5	
4-2020	05-Oct-21	12	23			17.5	
(RAA) Running Annual Average						16.75	100 ug/L