







Facilities Comprehensive Inspection Report

General Site Information		
Location	Lions Pavilion Memorial Park	Date: Jan, 2020
Inspector:	Kevin Green Facilities Manager	

Pavilion Information		
Address:	250 Owen Sound Street	
Site Location:	Main St E and Owen Sound St Dundalk	
General Information	Capacity 144 persons Not Accessible	Size: Main Hall 35' X 60'
		
Structure:	Materials: Block Wall Steel Roof Truss Roof Block Interior Walls Steel Exterior Doors Four Overhead Doors	Amenities: 20- 8' Tables 100 Chairs Activities: Located in Municipal Park Walking Trails Playground Sport Court Pool
	Perimeter: Concrete Walkway Gravel/ Screenings Grass area	
Kitchen: Yes	Stove /Refrigerator	



Facility Inspection Report:		
Reference:	Issue:	Date Repair
	Concrete floor sinking all corners	May not be able to fix. Problem will existing structure be strong enough to hold together during fix
	Trees trimmed for visibility	Continue in 2020
	Pavilion Roof repainted or replaced	When funds are available

Projected 10-year capital expenditure:

- Pavilion to be replaced with multiuse facility.
-